



SAMPLE

Certificate of Analysis

Customer

Approval Date:

Vessel / Tank #:

Reference Number:

Batch Number:

Customer Batch Number:

Product Name JEFFCOOL E-100

Sample ID

Test Details

Test Description	Results	Units	Specifications		Method
			Min	Max	
Appearance	Pass				ASTM E2680
Water Content	3.45	wt %	1.00	4.00	ASTM E203
Specific Gravity at 15.56°C	1.12		1.12	1.15	ASTM D4052
Reserve Alkalinity, 10mL	13.4	mL	10.5	14.0	ASTM D1121
pH, 33 % (v/v) Aqueous	10.08		10.00	10.70	ASTM D1287
Color	Red				Visual
Freeze Point, 50% Solution	-36	°F		-34	ASTM D3321
Chlorides	16	mg/L		25	ASTM D5827

Product meets or exceeds all requirements except where noted.

Lot Number and Traceability: Traceability may be maintained through the Batch number indicated in this document.

Notes: