#### **GREASE TRAP DOSAGE RATES**

### **Initial Dosage:**

Mix and let stand no longer than 1 hour while cleaning trap. (Remove solids and liquids.) Pour mixture into cleaned trap.

# GREASE TRAP SIZE WASTE-GO WARM WATER

0-100 gallons	2lb	4 gallons
100-500 gallons	4lbs	5 gallons
500-1,000 gallons	8lbs	10 gallons
1,000-2,000 gallons	12lbs	15 gallons

## **Maintenance Dosage:**

Apply every night after all clean-up is done to a drain leading to the grease trap.

#### GREASE TRAP SIZE WASTE-GO WARM WATER

0-100 gallons	½ cup	1 gallon
100-500 gallons	1 cup	2 gallons
500-1,000 gallons	2 cups	4 gallons
1,000-2,000 gallons	4 cups	8 gallons

Dosage Rates may vary depending on flow, meals served, and sanitizers used. Adjust as needed.

# SEWAGE TREATMENT PLANTS / LAGOONS / LIFT STATIONS / COMMERCIAL SEPTIC TANKS

#### **Initial Dosage:**

Amount calculated by total volume of tank / lagoon to be treated. Apply 5 days in a row.

- 1 lb. for 0 16,000 gallons of volume if tank is dead or has no activity
- 1 lb. for 0 25,000 gallons of volume if tank has some activity but also has solids buildup and scum
- 1 lb. for 0 50,000 gallons of volume if tank has some activity and minimal buildup

**Example:** If you have 300,000 gallons total volume with solids build up and scum, you would need 300,000 / 25,000 = 12 pounds per day for 5 days in a row as an initial dosage.

#### **Maintenance Dosage:**

• 1 lb. for each 100,000 gallons as a weekly maintenance dosage.

**Example:** If you have 300,000 gallons total volume the maintenance dosage would be 3lbs per week. This dosage can be adjusted as needed. If solids and scum start to build up, increase the weekly dosage.